

Thermally Modified Wood Collection Cladding Bid Specification Sheet

- Name: UFP-Edge Thermally Modified Wood Collection
- Profiles:
 - Nickle gap T&G
 - W4 T&G
- Sizes: 1x6 & 1x8
- Actual:
 - 11/16" Thick
 - 6" – 5 3/8" Wide
 - 8" – 7 1/8" Wide
- End Matched
- Finishes: Factory Applied Coatings
 - 6 Colors: Timber Ridge, Glacier, Lost Trail, Big Sky, Wood Smoke, Back Country
 - 2 Coat - 5 sides
- Unfinished:
 - Ponderosa Pine
 - Vertical Grain Hemlock
- Lengths: 8' – 16'
- Texture: Wire Brush
- Texture Unfinished: Smooth
- Species
 - Prefinished: Ponderosa Pine
 - Unfinished: Ponderosa Pine or VG Hemlock
- Grade: #2 & Better
- Warranty: 20-year limited (substrate)
- Packaging: 6 Piece Sub Bundles
- Applications: (Interior and exterior uses)
 - Exterior siding
 - Exterior soffit
 - Ceilings
 - Accent walls
- Manufacturing location: Bonner, MT



T&G nickel gap reveal end-matched



WP4/T&G end-matched

Flame Spread Test Results

Natural/not painted

SUMMARY OF TEST RESULTS

Specimen I.D.: UFP EDGE Thermally Modified Wood by UFP Industries, Inc.


ASTM E84 Test Results

FLAME SPREAD INDEX	SMOKE DEVELOPED INDEX
130	125

*See Section 8 for additional information and commentary

For INTERTEK B&C:

COMPLETED BY: Scott Gingrich
Technician Team Lead –
TITLE: Fire Testing
SIGNATURE: 
Digitally Signed by: Scott Gingrich
DATE: 06/22/21

REVIEWED BY: Ethan Grove
TITLE: Manager – Fire Testing
SIGNATURE: 
Digitally Signed by: Ethan Grove
DATE: 06/22/21

SDG:ddr

Prepainted White

SUMMARY OF TEST RESULTS

Specimen I.D.: UFP EDGE Thermally Modified Wood by UFP Industries, Inc.


ASTM E84 Test Results

FLAME SPREAD INDEX	SMOKE DEVELOPED INDEX
130	105

*See Section 8 for additional information and commentary

For INTERTEK B&C:

COMPLETED BY: Scott Gingrich
Technician Team Lead –
TITLE: Fire Testing
SIGNATURE: 
Digitally Signed by: Scott Gingrich
DATE: 06/25/21

REVIEWED BY: Ethan Grove
TITLE: Manager – Fire Testing
SIGNATURE: 
Digitally Signed by: Ethan Grove
DATE: 06/25/21

SDG:ddr